www.jbctools.com

INSTRUCTION MANUAL

Compact
Micro Tweezers Station

Ref. CP-QF

Packing List

The following items are included:

CP Control Unit ..... 1 unit
Ref. CP-1F (120V)
CP-2F (230V)
CP-9F (100V)

Adjustable Micro Tweezers ..... 1 unit
Ref. AM120-A

Power Cord ..... 1 unit
Ref. 0023715 (120V)
0023714 (230V)
0024092 (100V)

Brass Wool ..... 1 unit
Ref. CL6210

Sponge ..... 1 unit
Ref. S0354

Manual ..... 1 unit
Ref. 0026108

Features



Adjustable Micro Tweezers
Ref. AM120-A



Adjustable Stand

Adjust the tool stand to suit your work position.



Cable Collector (Ref. CC1001)

Place the cable on the collector so that the working area is free of cable.





Tip Cleaner

Select the option to suit your needs and improve the thermal transfer of the tip.

Splashguard
Ref. 0017576
When using the brass wool. it prevents splashing of solder particles.

Antisplash Membrane
Ref. 0017574
Prevents splashing and keeps the work area clean.

Brass Wool
Ref. CL6210
Very effective cleaning method. Leaves a small layer of solder on the tip preventing oxidation between cleaning and rewetting.





If the tip is very dirty, JBC recommends first cleaning it with the wiper to remove excess solder.

Wiper
Ref. CL0160
A temperature resistant receptacle for removing excess solder by gently tapping or wiping.

Removing the Splashguard

1. Unlock the splashguard.



2. Lift off.



More cleaning options (not supplied):



Inox Wool
Ref. CL6205
Stronger cleaning method than brass wool.



Metal Brush
Ref. CL6220
When used carefully, it provides a more thorough cleaning.

Wiper
Ref. CL0160



Tapping:
Tap gently to remove excess solder.



Wiping:
Use the slots to remove remaining particles.

Sponge
Ref. S0354



The softest cleaning method. Keep the sponge damp with distilled water when working to avoid tip wear.

Changing Cartridges

1. Removing



Place the cartridges in the extractor and pull to remove the cartride.

2. Positioning



Place the tweezers on top of the new cartridge and press down slightly.

3. Inserting



Use the holes for fixing the cartridges*.

***Important**
It is essential to insert the cartridges as far as the mark for a proper connection.

4. Rotational Cartridge Alignment



Slightly turn the wheels to align the cartridges as required.

5. Vertical Cartridge Alignment



Close the tweezers and the rear wheel allows the cartridges to be equally aligned en vertical direction.

Compatible Cartridges

The CP stations work with C120 cartridges and AM120 Ajustable Micro Tweezers. Find the model that best suits your soldering needs in **www.jbctools.com**



Conical Bent



Blade



Chisel Bent

Operation

The JBC Exclusive Heating System

This revolutionary technology is able to recover tip temperature extremely quickly.
This allows the user to work at a lower temperature.
As a result, tip life increases by 5.

1. Work



When the tool is lifted from the stand the tip will heat up to the selected temperature.



· Change temperature
(from 90 to 450ºC)
Steps ± 5
Steps ± 50

Through menu settings:
· Select temperature levels
· Fix one temperature

2. Sleep



When the tool is in the stand, the temperature falls to the preset sleep temperature.

Through menu settings:
· Change Sleep temperature
· Set Sleep delay
(from 0 to 9 min or no Sleep)

3. Hibernation



After longer periods of inactivity, the power is cut off and the tool cools down to room temperature.

Through menu settings:
· Change Hibernation delay
(from 0 to 35 min)

Control Process

Work Screen



Menu Screen

Default PIN: 0105



Troubleshooting

Station troubleshooting available on the product page at www.jbctools.com

Parameters

Be careful when using these parameters as they may reduce the tip life if not used properly. Please follow the recommended guidelines:

Station Settings

Parameter Description	Recommendations	Warnings
Temperature Unit Celsius (ºC) or Fahrenheit (ºF)	N/a	
Maximum Temperature Set the maximum temperature to work with. Max. temp by default is 400°C (750°F). This is considered high enough to work with most lead-free applications.	The station temperature range is 90-450ºC (190-840ºF). Change the temperature limits when working with less common applications such as low / high melting point soldering (HMP) or plastics (e. g. riveting).	⚠ In most cases, working with temperatures over 400°C (750°F) can damage the PCB and its components. Even in short time periods of tip contact with the soldering joint, the flux may not work properly and could seriously reduce tip life. If the solder joint requires more power (e.g. multilayered or high dissipation boards), JBC strongly recommends using other aids like preheaters.
Minimum Temperature Set the minimum temperature to work with. Min. temp. by default is 200ºC (392ºF). This is considered to be a proper starting point for leaded applications.		
Metronome This activates a beep sound. Frequencies vary from 1 to 50 seconds.	Useful for setting a work rate in repetitive jobs. The beep lets you know the length of time the tip must be in contact with the soldering joint.	N/a
Beep Enable/disable the beep sound of the keypad.	N/a	N/a
QST Enable/disable QST.	N/a	N/a
Pin Enable/disable pin prompt.	N/a	N/a
Change Pin Change the default security PIN number (0105).	The PIN must be entered every time a parameter is changed.	N/a

Tool Settings

Parameter Description	Recommendations	Warnings
Fix One Temperature Fix a value within the temperature range of the station (90-450ºC/190-840ºF).	Ideal for soldering more than one component at a specific temperature. The station will reject any attempt to change the temperature.	N/a
Temperature Levels Set Similar to “Fix one temp” parameter. In this case, the user can set up to 3 values for different power requirements.	This allows a quick change between 3 different temperatures. Set them according to the allowed values for your soldering applications.	N/a
Sleep Delay Set the time that the tool will remain at the selected temperature when in the stand before entering sleep mode. The tip temperature will then drop to the Sleep temperature.	Because our tools reach the working temperature from the deafult Sleep mode in only a few seconds, this parameter is preset to 0 min. Once the tool is returned to the stand the temperature will automatically drop to the sleep temperature, extending tip life and avoiding oxidation. Retinning the tip before placing the tool in the stand will protect the tip and extend its life.	⚠ Setting these parameters to higher values will unnecessarily accelerate oxidation and shorten tip life especially when working with temperatures up to 450°C (840°F).
Sleep Temperature This is the set temperature the tip reaches when returned to the stand.	The sleep temperatures are set to achieve a balance between preventing oxidation and reaching the working temperature in a few seconds.	

Tool Settings

Parameter Description	Recommendations	Warnings
Hibernation Delay Set the time the tool will remain at Sleep temperature before entering the Hibernation mode. At this time, the power supply is cut off and the tip remains at room temperature.	This function completely protects the tip from oxidation during long periods of inactivity while the tool is in the stand. Retinning the tip before placing the tool in the stand also helps prevent oxidation and extends the life of the tip.	⚠ Increasing the default value will accelerate oxidation and shorten the tip life.
Temp Adjustment It provides a more precise adjustment between the selected temperature and the actual one.	Set values within ±50°C (± 90°F) to achieve zero error. JBC strongly recommends the use of TID-A or TIA-A Thermometers to obtain precise readings.	⚠ When the user changes the cartridge type, the parameter should be reset to 0°C/F or to the value needed for this cartridge. E.g. If a correction of +20°C (+36°F) is set for a thick cartridge and then the user changes to a thinner one whitout resetting the temperature adjustment, he would be working at a higer temperature than needed for this thinner cartridge, which does not need any temperature adjustment.

USB Connector

Download the latest software from our website to update your soldering station.

JBC Updater
www.jbctools.com/software.html

Update the station software via USB connection:

JBC Web Manager
www.jbctools.com/manager.html

Manage and monitor as many stations as your PC can handle by using the JBC Web Manager. You can export data to another PC.



Manager Settings
Change settings for a group of JBC stations at the same time.

Register Settings
Create graphs of the soldering process in real time showing power and temperature data.

Maintenance

Before carrying out maintenance, always allow the equipment to cool.

- Clean the station screen with a glass cleaner or a damp cloth.



- Use a damp cloth to clean the casing and the tool. Alcohol can only be used to clean the metal parts.

- Periodically check that the metal parts of the tool and stand are clean so that the station can detect the tool status.

- Maintain tip surface clean and tinned prior to storage in order to avoid tip oxidation. Rusty and dirty surfaces reduce heat transfer to the solder joint.

- Periodically check all cables and tubes.

- Replace any defective or damaged pieces. Only use original JBC spare parts.

- Replace a blown fuse as follows:

1. Pull off the fuse holder and remove the fuse. If necessary use a tool to lever it off.

2. Insert the new fuse into the fuse holder and return it to the station.



-

When this warning appears on the main screen Earthing Fuse must be replaced



- Repairs should only be performed by a JBC authorized technical service.

Safety

It is imperative to follow safety guidelines to prevent electric shock, injury, fire or explosion.

- Do not use the units for any purpose other than soldering or rework. Incorrect use may cause fire.

- The power cord must be plugged into approved bases. Be sure that it is properly grounded before use. When unplugging it, hold the plug, not the wire.

- Do not work on electrically live parts.

- The tool should be placed in the stand when not in use in order to activate the sleep mode. The soldering tip, the metal part of the tool and the stand may still be hot even when the station is turned off. Handle with care, including when adjusting the stand position.

- Do not leave the appliance unattended when it is on.

- Do not cover the ventilation grills. Heat can cause inflamable products to ignite.

- Avoid flux coming into contact with skin or eyes to prevent irritation.

- Be careful with the fumes produced when soldering.

- Keep your workplace clean and tidy. Wear appropriate protection glasses and gloves when working to avoid personal harm.

- Utmost care must be taken with liquid tin waste which can cause burns.

- This appliance can be used by children over the age of eight and also persons with reduced physical, sensory or mental capabilities or lack of experience provided that they have been given adequate supervision or instruction concerning use of the appliance and understand the hazards involved. Children must not play with the appliance.

- Maintenance must not be carried out by children unless supervised.

Notes

Notes

Notes

Specifications

CP-1QF 120V 50/60Hz. Input fuse: 2A. Output: 23,5V. Control Unit model: **CP-1F**
CP-2QF 230V 50/60Hz. Input fuse: 1A. Output: 23,5V. Control Unit model: **CP-2F**
CP-9QF 100V 50/60Hz. Input fuse: 2A. Output: 23,5V. Control Unit model: **CP-9F**

- Output Peak Power CP-F:	80W
- Temperature Range:	90 - 450 °C / 190 - 840 °F
- Idle Temp. Stability (still air):	±1.5ºC / ±3ºF (Meets and exceed IPC J-STD-001)
- Temp. Accuracy:	±3% (Using reference cartridge)
- Temp. Adjustment:	±50ºC / ±90ºF (Through station menu setting)
- Tip to Ground Voltage/Resistance:	Meets and exceed ANSI/ESD S20.20-2014 IPC J-STD-001F
- Earthing Fuse:	F 1.25A
- Connections:	USB connector station-PC RJ12 connector
- Ambient Operating Temp.:	10 - 50 ºC / 50 - 122 ºF
- Control Unit Dimensions / Weight: (L x W x H)	170 x 176 x 145 mm / 2.8 kg 6.7 x 6.9 x 5.7 in / 6.17 lb
- Total Net Weight:	3kg / 6.61 lb
- Total Package Dimensions / Weight: (L x W x H)	234 x 234 x 258 mm / 3.15 kg 9.2 x 9.2 x 10.2 in / 6.94 lb

Complies with CE standards
ESD protected housing “skin effect”

Warranty

JBC's 2 year warranty covers this equipment against all manufacturing defects, including the replacement of defective parts and labour.

Warranty does not cover product wear or misuse.

In order for the warranty to be valid, equipment must be returned, postage paid, to the dealer where it was purchased.

Get 1 extra year JBC warranty by registering here: https://www.jbctools.com/productregistration/ within 30 days of purchase.

This product should not be thrown in the garbage.
In accordance with the European directive 2012/19/EU, electronic equipment at the end of its life must be collected and returned to an authorized recycling facility.

www.jbctools.com

0026108-1120